CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 17/10/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 12-10-18

Customer ID : Footing Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 17/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	17/10/2018	149.60 X 151.26 X 149.75	22629	**8.652**	524.4	23.2	22.8
2	Footing Concrete	M25	10/10/2018	17/10/2018	150.43 X 151.75 X 149.38	22828	**8.882**	520.0	22.8	
3	Footing Concrete	M25	10/10/2018	17/10/2018	149.30 X 149.71 X 150.35	22352	**8.566**	501.4	22.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/11/2018

Lab ID : **CP-2018-12-03-05**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 12-10-18

Customer ID : Footing Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	07/11/2018	149.72 X 149.41 X 150.00	22369	**8.180**	617.6	27.6	27.5
2	Footing Concrete	M25	10/10/2018	07/11/2018	149.04 X 151.17 X 149.36	22531	**8.621**	597.8	26.5	
3	Footing Concrete	M25	10/10/2018	07/11/2018	149.62 X 151.82 X 149.85	22715	**8.311**	646.5	28.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TE

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	: **CP-2018-12-03-05**	**Date: 17/10/2018**
Project Name	: Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07	
Agency	: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054	
Customer's Reference	: EE(Project)/Ynk Zone/wo/12/2018-19	
Date of Receipt	: 12-10-18	
Customer ID	: Footing Concrete	
Sample Type /Size	: 150X150X150 mm	
Sample grade/Age	: M25 / 7 Days Compressive Strength	
Reference to BIS codes	: IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5	
Date of test	: 17/10/2018	

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	17/10/2018	151.24 X 150.00 X 151.51	22687	**8.734**	528.6	23.3	22.9
2	Footing Concrete	M25	10/10/2018	17/10/2018	149.92 X 150.95 X 150.45	22630	**8.794**	517.2	22.9	
3	Footing Concrete	M25	10/10/2018	17/10/2018	150.38 X 151.67 X 151.92	22809	**8.308**	516.4	22.6	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL P
R KARTHIK RECH
Authorized Signa
Quality Mana

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

: **CP-2018-12-03-05** **Date: 07/11/2018**

ne : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

: Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Reference : EE(Project)/Ynk Zone/wo/12/2018-19

eipt : 12-10-18

D : Footing Concrete

pe /Size : 150X150X150 mm

de/Age : M25 / 28 Days Compressive Strength

o BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

: 07/11/2018

entification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
ting Concrete	M25	10/10/2018	07/11/2018	150.20 X 151.74 X 149.45	22792	**8.400**	637.8	28.0	27.5
ting Concrete	M25	10/10/2018	07/11/2018	151.04 X 151.89 X 149.21	22941	**8.820**	606.4	26.4	
ting Concrete	M25	10/10/2018	07/11/2018	150.44 X 150.04 X 150.39	22572	**8.887**	636.6	28.2	

Average Compressive Strength (N/mm^2)
23.0

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

FOR CIVIL Pro.

THIK RECHAN
horized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

: 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com
il.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 17/10/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	12-10-18
Sample ID No	:	2018-12-03-05 /05
Customer ID	:	Footing Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	17/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	17/10/2018	151.44 X 151.90 X 151.44	23004	**8.996**	549.3	23.9	23.0
2	Footing Concrete	M25	10/10/2018	17/10/2018	150.16 X 149.87 X 150.35	22505	**8.527**	516.6	23.0	
3	Footing Concrete	M25	10/10/2018	17/10/2018	149.70 X 150.44 X 149.48	22522	**8.279**	499.8	22.2	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/11/2018

Lab ID : **CP-2018-12-03-05**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 12-10-18

Customer ID : Footing Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	07/11/2018	149.76 X 149.22 X 151.36	22348	**8.294**	613.8	27.5	27.4
2	Footing Concrete	M25	10/10/2018	07/11/2018	149.21 X 150.90 X 149.32	22516	**8.152**	585.5	26.0	
3	Footing Concrete	M25	10/10/2018	07/11/2018	149.41 X 149.29 X 151.26	22305	**8.705**	642.8	28.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro BANGALORE
Sig.....
Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 17/10/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 12-10-18

Customer ID : Footing Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 17/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	17/10/2018	150.81 X 149.33 X 151.52	22519	**8.181**	523.6	23.2	22.5
2	Footing Concrete	M25	10/10/2018	17/10/2018	149.65 X 151.86 X 151.67	22725	**8.254**	508.0	22.4	
3	Footing Concrete	M25	10/10/2018	17/10/2018	150.72 X 150.87 X 151.50	22739	**8.270**	500.8	22.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 07/11/2018

Lab ID : **CP-2018-12-03-05**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 12-10-18

Customer ID : Footing Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	07/11/2018	151.95 X 151.72 X 151.06	23055	**8.467**	622.8	27.0	27.3
2	Footing Concrete	M25	10/10/2018	07/11/2018	150.37 X 149.79 X 151.95	22525	**8.827**	595.0	26.4	
3	Footing Concrete	M25	10/10/2018	07/11/2018	150.97 X 150.01 X 150.25	22648	**8.453**	644.5	28.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro

R KARTHIK RECHA
Authorized Signato
Quality Manag

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 17/10/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	12-10-18
Customer ID	:	Footing Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	17/10/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	17/10/2018	151.46 X 149.50 X 151.87	22643	**8.372**	532.7	23.5	22.9
2	Footing Concrete	M25	10/10/2018	17/10/2018	149.13 X 151.05 X 150.10	22526	**8.721**	500.3	22.2	
3	Footing Concrete	M25	10/10/2018	17/10/2018	149.27 X 151.63 X 150.54	22634	**8.609**	518.5	22.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 07/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 12-10-18

Customer ID : Footing Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Footing Concrete	M25	10/10/2018	07/11/2018	150.81 X 151.47 X 151.94	22843	**8.163**	619.1	27.1	27.2
2	Footing Concrete	M25	10/10/2018	07/11/2018	150.57 X 149.18 X 151.04	22461	**8.368**	589.7	26.3	
3	Footing Concrete	M25	10/10/2018	07/11/2018	149.00 X 149.47 X 150.30	22272	**8.747**	631.0	28.3	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE
Sig.....
Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 02/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 29-10-18

Customer ID : Column Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 02/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	26/10/2018	02/11/2018	150.69 X 151.63 X 151.34	22848	**8.490**	533.2	23.3	22.8
2	Column Concrete	M25	26/10/2018	02/11/2018	150.16 X 151.52 X 150.47	22751	**8.204**	518.5	22.8	
3	Column Concrete	M25	26/10/2018	02/11/2018	149.60 X 149.26 X 149.12	22330	**8.113**	499.9	22.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 23/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 29-10-18

Customer ID : Column Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	26/10/2018	23/11/2018	151.19 X 150.72 X 151.01	22787	**8.856**	625.2	27.4	27.2
2	Column Concrete	M25	26/10/2018	23/11/2018	149.26 X 151.39 X 149.01	22596	**8.859**	591.4	26.2	
3	Column Concrete	M25	26/10/2018	23/11/2018	151.80 X 151.86 X 150.82	23051	**8.246**	648.6	28.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 02/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 29-10-18

Customer ID : Column Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 02/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	26/10/2018	02/11/2018	151.37 X 151.44 X 149.22	22924	**8.643**	546.3	23.8	22.8
2	Column Concrete	M25	26/10/2018	02/11/2018	149.30 X 151.53 X 151.35	22624	**8.762**	501.5	22.2	
3	Column Concrete	M25	26/10/2018	02/11/2018	151.64 X 150.46 X 149.04	22814	**8.290**	512.8	22.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 23/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 29-10-18

Customer ID : Column Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	26/10/2018	23/11/2018	150.95 X 151.43 X 150.92	22858	**8.508**	637.7	27.9	27.5
2	Column Concrete	M25	26/10/2018	23/11/2018	149.10 X 151.34 X 150.47	22566	**8.947**	586.7	26.0	
3	Column Concrete	M25	26/10/2018	23/11/2018	149.55 X 150.50 X 150.90	22507	**8.140**	646.6	28.7	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 02/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 29-10-18

Customer ID : Column Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 02/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	26/10/2018	02/11/2018	149.34 X 150.83 X 151.90	22525	**8.475**	523.9	23.3	22.7
2	Column Concrete	M25	26/10/2018	02/11/2018	150.14 X 149.35 X 150.58	22424	**8.783**	496.8	22.2	
3	Column Concrete	M25	26/10/2018	02/11/2018	151.98 X 151.45 X 150.90	23018	**8.537**	522.2	22.7	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 23/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 29-10-18

Customer ID : Column Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 23/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Column Concrete	M25	26/10/2018	23/11/2018	151.98 X 149.31 X 149.21	22692	**8.201**	614.6	27.1	27.4
2	Column Concrete	M25	26/10/2018	23/11/2018	151.10 X 149.85 X 149.22	22643	**8.848**	590.4	26.1	
3	Column Concrete	M25	26/10/2018	23/11/2018	151.14 X 150.19 X 149.65	22700	**8.111**	656.1	28.9	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 10/11/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 05-11-18

Customer ID : Pool Base Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 10/11/2018

SL No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pool Base Concrete	M25	03/11/2018	10/11/2018	149.90 X 150.08 X 149.54	22497	**8.223**	527.1	23.4	23.0
2	Pool Base Concrete	M25	03/11/2018	10/11/2018	151.14 X 150.24 X 151.88	22707	**8.565**	512.8	22.6	
3	Pool Base Concrete	M25	03/11/2018	10/11/2018	150.48 X 151.36 X 149.86	22777	**8.925**	523.3	23.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 01/12/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	05-11-18
Sample ID No	:	2018-12-03-05 6
Customer ID	:	Pool Base Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	01/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Pool Base Concrete	M25	03/11/2018	01/12/2018	150.07 X 149.79 X 151.87	22478	**8.336**	607.4	27.0	27.2
2	Pool Base Concrete	M25	03/11/2018	01/12/2018	149.58 X 150.66 X 151.02	22536	**8.846**	591.4	26.2	
3	Pool Base Concrete	M25	03/11/2018	01/12/2018	150.91 X 149.77 X 149.53	22601	**8.340**	642.2	28.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |